



Net Zero Salt Cross Garden Village study

Benjamin Mousseau CTO & Partnerships Co-Founder





About us

Overview



Urbanomy is a subsidiary of EDF Group, specialising in integrated urban and energy planning.

We advise local authorities, developers and landowners at the pre-construction stage on how to create net-zero blocks, districts, and communities using low and zero-carbon energy technologies. We adopt a systemic approach to take into account the complexity of Smart Local Energy Systems through spatial analysis and time of use balance. We develop our recommendations using a suite of in-house modelling tools, created and refined over the past decade by EDF's international Research & Development teams.

- An integrated vision
- A human-centric approach
- Technology-agnostic offers
- An operator-logic perspective at the forefront of innovation















Researchers across the world

12 centres

3 France United Kingdom Germany Italy USA China Singapore

Copyright Urbanomy - 2021

" The way we humans live on earth now is sending biodiversity into a decline. This is happening as a result of bad planning and human error.... ??

Sir David Attenborough







NET To accelerate Britain's transition to net zero through integrated urban and energy planning. 2050



Long-term viability is about taking the right decisions early in the process

Cost of change



City /Region

Block

Portfolio

banomv ODE GROU

Some examples of what we do









Caisse des Dépôts 2050 environmental strategy +60 buildings portfolio



Moscow Greenfield City platform



Sanya Multi-energy district cooling system

The Project

Salt Cross Garden Village



Exemplar garden village development identified in the West Oxfordshire Local Plan



Smart and Fair Futures project led by the Low Carbon Hub within the Local Energy Oxfordshire (LEO)



2,200 homes

Homes to include at least 50% of affordable Rent and Own



+1,000 pupil capacity schools



1 health centre



1 science park of more than 40 hectares



1 Park & Ride including 45 charge points







SOURCE - © West Oxfordshire District Council - Area Action Plan





WEST OXFORDSHIRE DISTRICT COUNCIL



Copyright Urbanomy - 2021

The Ambitions

Salt Cross Garden Village

West Oxfordshire published a draft Area Action Plan setting up core requirements:

- Net Zero Development
- Low Energy Use in new buildings
- Low carbon energy supply
- No use of fossil fuels on site

Objectives of the study:

- Provide quantifications and insights on local energy system options
- Provide options to minimize the energy use and maximise energy efficiency
- Provide an integrated vision including electrification of transport
- Assess the amount and value of flexibility on-site



Source: WODC – Area Action Plan





Project Local Energy Oxfordshire (LEO)

Smart and Fair Futures Eynsham

The study is supporting the <u>Eynsham Smart and Fair</u> <u>Futures project led by the Low Carbon Hub as part of Project</u> <u>LEO (Local Energy Oxfordshire)</u>, one of four national demonstrator projects focusing on smart local energy systems.

The study has been conducted in collaboration with Project LEO partners including Low Carbon Hub, the University of Oxford, Oxford Brookes University and Scottish and Southern Electricity Network (SSEN – Lead of the consortium) among others, as well as other local stakeholders West Oxfordshire District Council (WODC)and low carbon community action group Eynsham GreenTEA

Urbanomy's new study builds on the published Energy Plan (EP) for the area to assess the energy supply and demand, including smart electric mobility, at the garden village development and its impact on the local grid and the wider area.



Funding provided through the Government's modern industrial strategy by Innovate UK, part of UK Research and Innovation.







Source: <u>https://project-leo.co.uk/</u>



<u>Transition Eynsham Area (GreenTEA)</u>, the local low carbon group and founding community shareholder of the Low Carbon Hub CIC, are chairing the Local Steering Group working closely with the Low Carbon Hub in developing and implementing the smart and fair futures trial. Also on the steering group are representatives of West Oxfordshire District Council and some of the local parish councils.



Copyright Urbanomy - 2021

Overview of our methodology



Overview of our methodology – Building energy



Building typologies are first defined for the expected types of buildings to be built in the new development, including residential and non-residential buildings. These typologies will be overlayed with their thermal characteristics, fabric assumptions, and orientation to inform the calculations.

The **energy needs** for the 4 main uses: <u>heating, air</u> <u>conditioning, domestic hot water and unregulated</u> <u>electricity</u>, will then be assessed and represented as a load curve. Further study calibrate this assessment even further, for example amending the heating setpoint and air conditioning temperatures, as well as the ventilation specifications.



Overview of our methodology – Electric Vehicles



EVSE infrastructure for the new development will be assessed in terms of number and types of charge points to be installed.

Evaluation of EV demand: From the EV charge point needs evaluation, the total electricity demand for EVs is assessed through a database of real world profiles of electricity demand.

Solar canopy and parking energy system assessment to provide a combined load curve for a parking facility. This step uses an advanced optimisation toolbox allowing us to assess the PV potential for solar canopies as well as the demand from parked EVs.



V1G/V2G recommendations and potential for the EV parked at the new development. The potential for local flexibility and services to the local grid is assessed through an optimisation tool, which allows us to conduct a detailed evaluation of the benefits of V1G and V2G. both in terms of revenues and reduction of constraints for the local grid.

Overview of our methodology – Flexibility



Compilation of the outcomes of the energy and mobility studies of phase 1. Creation of an overall load curve for the energy demand and local energy production. 

24

Disclaimer and Copyright

The results presented in this study reflect the outcomes from simulations conducted by Urbanomy and are supporting a work in progress in the planning process of the Salt Cross Garden Village.

The outcomes might change according to evolutions in the requirements and design of the area.

The content of this presentation is copyright of Urbanomy, or the party credited as the provider of the content. You may not copy, reproduce, distribute, publish, display, perform, modify, create derivative works, transmit, or in any way exploit any such content, nor may you sell or offer it for sale, or use such content to construct any kind of database. You may not alter or remove any copyright or other notice from copies of the content.

For any requirement, please contact <u>contact@urbanomy.io</u>



SOURCE - © West Oxfordshire District Council - Area Action Plan



1.1. Energy needs in the buildings







Building mix assumptions





© West Oxfordshire District Council Salt Cross Garden Village – Area Action Plan (AAP) www.westoxon.gov.uk

- Terraced I
 - *Te*
 - Te Te
 - Med-Rise

- **1**
- 2
- Offices (4
 - Specialist
 - 1
- Schools (8
 F
 - =
- Retail (1,5)
 - Health (46
 - 1

Assumptions in coherence with the Area Action Plan of West Oxfordshire District council, and in line with Elementa Energy Study.



1595 buildings

Houses (133,000 sqm): 2 storeys	1554
erraced Houses (2 beds dw.) : 65 m ²	454
erraced Houses (3 beds dw.) : 90m²	748
erraced Houses (4 beds dw.) : 105m ²	352
(33,000 sqm): 5 storeys	12
-bed dwellings: 45m² (35 per building)	420
-bed dwellings: 65m² (22 per building)	264
0,000 sqm): 3 storeys	10
0 buildings of equal size	
offices (40,000 sqm): 3 storeys	10
0 buildings of equal size (or 9 in the	
Data Centre scenarios)	2
8,500 sqm): 2 storeys	
Primary School: 3563m ²	
Secondary School: 5600m ²	C
500 sqm): 3 storeys	0
5 buildings of equal size	
60 sqm): 3 storeys	1
building	

Summary of the demand scenario

Baseline scenario was established based upon assumptions from the Elementa study (2020 - AAP) scenario 4.2.

Typology	Fabric	Heating and DHW system	Energy Needs Modelling Conside		
Terraced	U values: Ultra low standard Floor: 0.08 Wall: 0.13 Roof: 0.10 Window: 0.8 Thermal Bridge: 0.04 Ventilation: 90% recovery Airtightness: <1m ³ /hr.m ²		90m ² dwelling size, N/S and E orientations, and standard UK beh		
Med-Rise		J values: Ultra low standard Floor: 0.08 Wall: 0.13 Roof: 0.10 Window: 0.8 hermal Bridge: 0.04 Air Sourced Heat pump (individual or communal) with flow and return temperature 65°C /50°C Heat pumps	65m ² dwelling size and standa behaviours		
Retail			Heat recovery from fridge installation generic behaviour for a retail u		
Health Centre			DHW similar to office behaviours, others based on generic health ur		
School			Based on UK school scheduling.		
Office			Standard UK practices for offices		
Specialist Office		Ventilation: 90% recoverywith low flowAirtightness: <1m³/hr.m²	Standard laboratory activities – Ada from Begbroke Science Park case.		





Principle of the energy need assessment

The assessment is based on the simulation of the behavior (thermal exchanges between the in-out door), by using a Dynamic Thermal Energy simulation



The geometry and the thermal characteristics of the components are considered.







Unitary Energy Consumption by Typology



Results reflects the level of information available at the time of the simulations and will be updated according to the latest updates in planning process

urbanomv



- ✓ The Dynamic Thermal Energy Simulation has been conducted on all typologies with the target of high thermal standard.
- ✓ The target of < 15 kWh/m2.yr of space heating demand is met for every typologies
- ✓ Very high standard has been applied for the building fabric and the thermal insulation, including thermal bridges simulation.
- ✓ Thermal uses (SH and DHW) results are very low proving the ability to reach ambitious targets, however, unregulated electricity and AC needs (not considered in SAP) are too high to reach the targeted EUI.

1.2. Energy scenarios







In a nutshell : 3 main energy scenarios with variations









Scenario 1 – Decentralised production system – Air/Water heat pumps

How does scenario 1 work?

- Each building is independent
- The space heating (SH) and the domestic hot water (DHW) are supplied by an air/water heat pump at 65°C
- A DHW storage is installed close to the heat pump to ensure potential flexibility which could be needed based on electricity prices, PV production and to limit quick load variation of the heat pump
- In summer, the heat pump can supply the cooling needs (if reversible heat pumps are used) or an additional air conditioning system is installed
- This scenario includes 4 variations : with data centre + with Heat Pump with Inverter Control, with data centre + with Heat Pump with on-off control, without data centre + with Heat Pump with Inverter Control, and without data centre + with Heat Pump with on-off control

SIMPLE REPRESENTATION | SCENARIO 1





Scenario 2.a - Heat network - Heat recovery from data centre and central heat pump

How does scenario 2.a work?

- This scenario assumes a central energy hub with the inclusion of a data centre in the business park as central production units for the district
- A centralized heat pump (65°C) is installed in the energy hub •
- The waste heat from the data centre is used to preheat the water to around 30°C
- A low temperature heat network (supply 65°C return 40°C) is used to connect all the buildings to the energy hub
- DHW buffer tanks are installed in the building or in the dwellings to ensure flexibility in the system
- For cooling, the option to use the heat pump in a reversible way (or to install an electric chiller) with the network as a cooling network • needs to be discussed in comparison to installing electrical climatization systems (because of the strong correlation with PV production and cooling needs).
- This scenario does not include variations : Heat Pump with Inverter Control only for the Energy Hub; •





Scenario 2.b - Heat network - Solar and shallow geothermal production

How does scenario 2.b work?

- The energy hub is the central production unit for the district
- Solar thermal panels are installed on the roof and/or around the energy hub according to the needs
- A centralised heat pump (65°C) is installed in the energy hub
- A borehole system is installed underground below the energy hub and/or below the solar thermal field according to needs. The geothermal borehole system is used as heat source for the heat pump and seasonal storage for the solar thermal production
- A low temperature heat network (supply 65° C return 40° C) is used to connect all the buildings to the energy hub
- DHW buffer tanks are installed in the building or in the dwellings to ensure flexibility in the system
- For cooling the option to use the heat pump in a reversible way (or to install an electric chiller) with the network as a cooling network needs to be discussed in comparison to installing electrical climatization systems (because of the strong correlation with PV production and cooling needs)
- This scenario does not include variations : Heat Pump with Inverter Control only for the Energy Hub;

SIMPLE REPRESENTATION | SCENARIO 2.b





Scenario 3.a - Production system – Water / water heat pumps on ambient loop supplied by the data centre

How does scenario 3.a work?

- The waste heat from the data centre is used to preheat the water and supply an ambient water loop $(25^{\circ}C 15^{\circ}C)$
- All buildings are connected to this ambient loop
- For each building, heat pumps using the ambient loop are installed as a heat source
- According to the use of the building and level of matching temporality of the heating and cooling needs, simple heat pumps, reversible heat pumps or thermo-refrigerating pumps will be installed
- Additional small heat-pumps will be installed to produce instantaneous DHW at dwelling levels
- This scenario includes 2 variations : with Heat Pump with Inverter Control and with Heat Pump with on-off control

SIMPLE REPRESENTATION | SCENARIO 3.a





LEGEND Heat pumps (water sourced) **EV Charge Points Domestic Hot Water** (DWH) storage * ΡV

Scenario 3.b - Production system – Water / water heat pumps on ambient loop supplied by borehole system

How does scenario 3.b work?

- Below the energy hub, a geothermal borehole system is supplying an ambient water loop $(25^{\circ}C 15^{\circ}C)$
- All building are connected to this ambient loop
- At each building, heat pumps using the ambient loop are installed as a heat source
- According to the use of the buildings and level of matching temporality of the heating and cooling needs, either simple heat pumps, reversible heat pumps or thermo-refrigerating pumps will be installed
- Additional small heat-pumps will be installed at the dwelling level to produce instantaneous DHW
- This scenario includes 2 variations : with Heat Pump with Inverter Control and with Heat Pump with on-off control

SIMPLE REPRESENTATION | SCENARIO 3.b





Copyright Urbanomy - 2021



Scenario comparison – annual values



excluded) :

Use of inverter-controlled technologies instead of ON/OFF → 30 to 40 % electricity savings •

- Use of **ambient loop maintained at 12°C by geothermal energy** → < 1% electricity savings •
- Use of 70°C district heating → + 130 to 150% electricity consumption (due to high thermal losses) •

■ Elec SH ■ Elec DHW ■ Elec Central HP ■ Elec Network pump ■ Elec AC ■ Elec AC-DC ■ Elec SE ■ Elec SE-DC



Concerning the final energy consumption of the buildings given the described scenarios (Data centre

Use of ambient loop maintained at 20°C by data centre or other source → 15 to 30 % electricity savings

1.3. Energy demand in the buildings







Load Curve: Daily and Yearly analysis







Copyright Urbanomy - 2021



Comparison



Copyright Urbanomy - 2021

Comparison of yearly peaks for building demand for the different scenarios



- **Unregulated electricity** is (by far) the most important part of the building energy demand when we analyse the load curve by use.
- The terraced houses and the specialist offices represent most of the building energy demand when we analyse the load curve by building typology.
- For the scenarios with a Data Centre, the demand is highly increased, despite a gain in the efficiency due to the waste heat recovery for the centralised scenarios (2-3), but mainly on the Ambient Loop solution (scenario 3).



Yearly building demand (GWh)	SCOP (Seasonal COP)
31.22	3.61
31.73	2.44
18.82	3.61
19.65	2.44
36.78	1.01
23.66	0.9
32.13	5.3
32.37	3.2
18.62	4.14
19.64	2.49

Comments and recommendations (1/4)

01

A very good envelop that minimises the heating need but may cause a high cooling need!

Window protection and good glazing to limit the air conditioning need

To minimise the air conditioning need potentially arising from such an efficient envelope, limiting 30% of the solar flux going inside is key to improving the energy efficient consumption of a building, both in terms of heating and cooling.

02

Quality of the envelop (walls, windows & thermal bridge)

The quality of the envelop is crucial for an optimal building energy efficiency : it is therefore essential to respect high requirements and standards. It is also key to choose good external insulation and reduce thermal bridges.

The very high building fabric standards applied in this study allow to reach very low thermal needs and an EUI of around 50 kWh/sqm/y in residential buildings, including unregulated electricity (EUI between 20 to 30kWh/sqm/y for space heating and DHW).



Efficient lighting and control

Due to the reduced thermal needs, the share of the unregulated electricity in the building needs is high. Lighting and electric appliances must be chosen with special attention to reach a further level of efficiency.

Lighting needs to be properly set and controlled to avoid too much heating gain. The standard would be 1W/m² for residential and 2W/m² for tertiary. Close monitoring of energy consumption is essential to quickly detect / correct potential issues and improve performance. Communicating more on this subject, for example by giving a comparison of the energy consumption of residents compared to a local benchmark within the neighbourhood, also makes it more tangible.



03

Efficient domestic appliance

Domestic appliances (such as ICT, HiFi, screens, cooking, fridges) also play a key role on long-run energy efficiency, and energy sobriety should be a key criteria for choosing these appliances, allowing long-run energy and cost savings.

Ventilation is a key factor in terms of energy efficiency, especially in residential buildings where it is operational 24/7. It can allow for the recovery of up to 90% of the heat.

06 Education

Ventilation

Reasonable consumption of energy should be encouraged by optimising the cost-benefit ratio of "green" behaviors (nudge can be a relevant answer).

Monitoring & benchmarking

Comments and recommendations (2/4)

08

Scenario 2 using a heat network (70/45 °C) seems inefficient in the case of Salt Cross Garden Village

- Scenario 2 appears to be inefficient for this project due to extremely • low energy linear density (0.5 MWh/ml, versus the minimum density usually used for profitability which is 3 MWh/ml). This is due to the high fabric quality of the buildings (small thermal needs) and to the large number of individual houses, leading to a long network with a large number of connections, meaning higher thermal losses.
- The thermal losses would be higher than the actual thermal needs of buildings (up to +1MW needs from thermal losses).



Scenario 3 (the ambient loop solution) would be a better hybrid solution than the fully centralised one

The low temperature ambient loop is favourable to avoid the significant thermal losses present in a district heating solution. However, they're usually used for smaller systems (50-100 houses), so it may be beneficial to instead consider several smaller loops rather than a village-wide one.

Heat recovery from the data centre increases the efficiency but adds a large load

- The heat recovery from the data centre increases the efficiency of the system but the choice of installing a data centre should not be made only for this purpose, as it largely increases the overall consumption.
- All the potential heat sources should be considered for waste heat recovery: wastewater heat recovery, local industries or implementing more solar thermal, similar to what is implemented in Scenario 2.b. However, solar thermal was not considered in the ambient loop scenarios as it draws the water at too high of a temperature with too much intermittency, and as the savings would not be able to cover the significant additional costs.



Scenario 1 (decentralised) also shows good efficiency. Here, the choice of heat pump technology, including its control is key

The domestic hot water is considered as semi-instantaneous production, which involves hourly storage. The heat pump is often used at partial load with impact on its COP. The use of a compressor with inverter control technology will increase the seasonal COP of the heat pumps. Currently, most of the Air/Water heat pumps (Scenario 1) use inverter controls, when most of the small Water/Water heat pumps (Scenario 3) have fixed speed compressors equivalent to an ON/OFF control system for partial load.

In the case of the Ambient Loop (Scenario 3), it's advised to add DHW storage capacity corresponding to daily storage. The storage addition will on one hand increase the COP of the Water/Water heat pump, but on the other hand allow the production of domestic hot water according to PV production, increasing self-consumption.

Low temperature emitters

Low temperature radiators would be an adapted solution for space heating given the low heating needs and the similar water temperature needs for DHW (60 deg.).

Comments and recommendations (3/4)

13

Scenario 3 could be of interest if the ambient loop is kept at 20°C rather than at 12°C.

Compared to scenario 1 (decentralized HP):

- The seasonal COP (in particular for space heating) is significantly improved in the case of the ambient loop at 20°C (with heat recovery from the data centre). In the case where the ambient loop is heated by the geothermal source only (12°C), the seasonal COP is only slightly improved as the external air temperature would be at the same order of magnitude.
- The total injection of heat from cooling processes in the • offices and specialists is lower than the total heat extracted for space heating and domestic hot water.
- The ambient loop appeal would increase if many heat • sources would be combined on the loop or if the district had a higher mix of usages (more tertiary, grocery, food storage etc...).



- both solutions in different ways.
- the right decision.



The borehole system as a pure source of energy looks to be inferior in this case, however it might be relevant for seasonal storage under the following conditions:

- The data centre is installed and uses free cooling in the • winter, and active cooling in the summer (with heat recovery to the ambient loop)
- Heat from wastewater is used as an additional heat • source
- Solar thermal is used as an additional heat source
- A higher share of buildings have cooling needs during • summer

Scenario 1 (decentralized) and 3 (ambient loop) should be compared based upon economic criteria.

The 2 scenarios are indeed relatively close in terms of their final energy consumption. Therefore, a more detailed study using different types of storages and control strategies, including PV self consumption (as shown with the Flexibility Scenario 3 and 4) could change the overall efficiency and economic balance of

Storage and the ambient loop are additional investments, air/water and water/water heat pumps represent different investment costs and involve specific operational costs which should be considered in order to make

2. On-site PV production







On-Site PV description

Average Square Metres and Footprint		Quantity	Tilt	APEX	Roof Coverage	Efficiency	Unitary Capacity	
	m ²	m²	Number of buildings	Angle / Degrees (°)	Coefficient (0 to 1)	Percentage	Percentage	kWp
Terraced houses 2 beds	65	36.1	454	40	0.5	70%	16%	2.64
Terraced houses 3 beds	90	50.0	748	40	0.5	70%	16%	3.66
Terraced houses 4 beds	105	58.3	352	40	0.5	70%	16%	4.27
Medium rise buildings	575	127.8	12	0	1	50%	16%	10.22
Health Centre	460	170.4	1	40	0.5	50%	16%	12.47
Offices	4000	1481.5	10	0	1	50%	16%	118.52
Retail	250	92.6	3	0	1	50%	16%	7.41
School 1	3563	1979.4	1	40	0.5	70%	16%	144.93
School 2	5600	3111.1	1	40	0.5	70%	16%	227.79
Specialist Offices	4000	1481.5	10	0	1	50%	16%	118.52
Park & Ride Solar Canopy								500

Assumptions taken regarding PV:

- Number of buildings is in coherence with the AAP. -
- Half of the retail buildings have tilted roofs; the other half have flat roofs. -
- A 16% PV module efficiency corresponds to moderate efficiency, and consequently, to a moderate and reasonable assumption.
- PV orientation have been optimised when relevant: default North/North-East/North-West orientations have been replaced by South/South-West/South-East orientations.


Local PV production (3/3)

Aggregated monthly PV Production for Salt Cross Garden Village (GWh)



Aggregated yearly PV Production for Salt Cross Garden Village (GWh)

77

Comments



PV Production is an important source of 01 local energy generation for the Garden Village

- Based on assumptions taken, the total annual PV potential (rooftop + solar canopy) is 8.85 GWh, with an average of 23 MWh per day (40-50MWh/day in summer, 5-10MWh/day in winter).
- This represents between 23% and 44% of the overall energy • demand (buildings + EV + P&R) – See table on the left.
- The self consumption rate is lower than the results of the Elementa Energy Study referenced in the AAP due to the wider scope of energy demand including unregulated electricity, AC and EV (see slide 104), and the assumptions of PV covering considering the types of roofs (see slide 67).

Park & Ride solar canopy is slightly increasing the self consumption.

The solar canopy of the Park & Ride represents only 440 MWh (5%) of the total yearly on-site production but is underutilised by the EV charging needs of the park & ride (see section 4.). There is therefore room to increase slightly the self consumption in the Garden Village by using the solar canopy.

03



More mixed used in the Garden Village would help to self-consume more PV by design.

• The Garden Village is mixed-use with a combination of residential buildings and office buildings but the addition of some uses with high demand during the day (retails, services) etc.) would ensure a higher PV self-consumption. As we can see on section 5., in summer, the PV generation potential greatly exceeds the building and EV energy demand.

• Solutions for storage and smart charging would help manage the demand and increase self-consumption, as shown in section 6..

3. Electric mobility demand (Garden Village)







Introduction

What will be the energy demand for Electric Vehicles in Salt Cross Garden Village?

Electric Vehicles (EVs) charging in the Garden Village will be a significant contributor to the site's energy demand. To assist in energy planning for the Garden Village, we used the predicted traffic model for the village in 2031 and its knowledge of EVs and the EV market to model what the daily energy demand profile will be for charging EVs at the site.





Number of charge points

The number of parking spaces and charge points are obtained following guidelines from the Area Action Plan (presubmission draft) by the West Oxfordshire District Council (p.144):

The absolute maximum car parking provision shall be 1 space per 60 m² of employment space with residential provision as below: Garden Village: I bed units - 0.75 non-allocated per property - 50% of non-allocated parking spaces 2 & 3 bed units - I off-street bay per property - 25% of non-residential development parking spaces 4+ bed units - I off-street bay per property plus the equivalent of I non-allocated bay per property





R&D UK Center



- All residential properties with a parking space

EV market penetration in 2030

The Future Energy Scenarios (2020 release) from the National Grid forecasts 4 scenarios regarding the uptake of battery electric vehicles (BEVs) in the UK by 2050.





2 scenarios are kept for this study:

1. High uptake = 11.4 million EVs in circulation by 2033. \rightarrow 38% of EVs

2. Steady Progression = 4.2 million EVs in circulation in 2033. \rightarrow 14% of EVs

Note: this forecast was released before the UK government announcement to ban sales of ICE vehicles by 2030. Therefore the "High uptake" scenario would seem the most reasonable for 2033.

Deriving an EV load curve: EV occupation behaviour

The assumed behaviour for a vehicle is as follows:



residents who are returning to the GV after working elsewhere or spending the

day out





Arrivals mostly include

employees coming from

outside the GV to work

The number of very short stays and drop-offs, for example for schools (arrive and depart without plugging-in) are negligible.

Vehicles park immediately once arriving at the GV.

Modelling results: 4 different cases





	Ĭ.	Ĭ.
s (%)	Employment Chargers (%)	Education Chargers (%)
kW	7kW 22kW 50kW	7kW 22kW 50kW
-	40 % 60 % -	40 % 60 % -
-	40 % 60 % -	40 % 60 % -
%	35 % 55 % 10 %	35 % 55 % 10 %
%	35 % 55 % 10 %	35 % 55 % 10 %

Modelling results: case 1





CASE 1

- 38% EV Penetration
- Residential Chargers: 80% 7kW, 20% 22 kW
- Employment Chargers: 40% 7 kW, 60% 22 kW
- Education Chargers: 40% 7 kW, 60% 22 kW

Comments and recommendations

01

The EV demand represents a relatively small percentage of the overall demand but can increase the peak demand significantly.

- The overall demand is increased between 4% and 8% by the electrification of transport in the village, in the highest penetration scenario (38% of EV).
- The peak demand is increased by the EV morning peak between 2% and 17%, without any smart charging management implemented.



02

The correlation of plugging time for the science park and the schools can result in a high morning peak

The morning peak (roughly 7AM-10AM) is quite high, mainly due to common arrival time for employment in the science park and for education at the schools (for teaching staff mainly as plug-in during drop-offs are negligible). The morning peak can be smoothed out by several measures for the employment and education segments, such as a system of incentives (e.g., adapted parking solutions and fees, flexible working hours) and smart charging (see Section 6.). This would reduce the impact on the grid.



03

The evening peak can be managed with smart management and night charging for the residential uses.

- The evening peak (roughly 4PM 7:30PM) remains important due to similar arrival hours in the residential parts of the Garden Village. A smart charging system could be implemented and encouraged for charging during the night to minimize the EV charging impact on the grid while allowing residents savings.
- The time window of this peak corresponds to high energy prices but also the DSO services availability window, leading to opportunities to provide flexibility, if the batteries have a SOC of above 30% and are aggregated.

4. Electric mobility demand (Park & Ride)





Park & Ride – Reminder of EAP results (2019) and adaptation to EV scenarios



Proposed design – AECOM - 2019



These results have been updated from the EAP study conducted in 2019 to reflect the scenarios defined in the above EV study for the charge points in the garden village. The park and ride demand and generation have been integrated in the overall demand of the Garden Village.

Park & Ride – Assumptions and cases



From the EAP (2019), the assumptions chosen for this study are the PV assumptions from the Scenario 2:







Comparison of the Net Energy Profiles of the 4 cases for the Park & Ride

7

No Rapid charging



- Low EV market penetration = lower EV charging peak around 95 kW in winter (vs. up to-145 kW in winter for high market penetration)
- In any configuration, local solar production will not be sufficient to allow full autonomy of the P&R throughout the year : connection to the electricity grid is required both to sell the surplus and to alleviate the shortage related to peak hours. Depending on costs, it can also be interesting to install local storage batteries to increase the self-consumption rate







Rapid charging (50KW)

Electric Mobility Total (EV + P&R)



- Lower EV market penetration = Lower EV consumption: peaks below 400 kW for both low EV penetration use cases, vs. up to more than 800 kW and 900 kW without and with rapid charging.
- In both cases, the peak is higher when rapid charging (50kW) units are included. •



5. Integrated load curve







108

Net demand per scenario (w. inverter system)



Copyright Urbanomy - 2021

Net demand per scenario (w. inv. system) – Comparison/Validation



6. 1. Flexibility Potential in buildings







The ReFlexBox Tool

- Simulates the operation of energy systems, consisting of single buildings located in the same grid area
- The tool assesses the flexibility potential of the designated area
- This allows to optimize and scale up best practice technologies.
- The replicability potential is based on experiences obtained in +10 smart grid demonstration projects of the ReFlex Project.

ReflexBox: replicability / scalability Simulation-based planning of smart grids

The model is developed in the project ReFlex -Replicability Concept for Flexible Smart Grids It aims to assist the cities and districts for local smart grid planning by replicating grids to the planned location and scalling them up to a desired size.

Current replication	and scalling are based o	on Biel-Benken pilot site i				
Input Data:						
1. Building climate :	Middle South Europe (Biel-Benke					
2. Building number:						
3. Building energy o	consumption :	Medium				
4. Weather condition (PV & temperature):						
5. Installations 🕑 PV installed 🕑 Battery installed						
Model Description	S	imulation				
(click me:)						
		0 ag 🏟 ag				
Pilot site		Site scalling Possibility distribution monte carlo runs				
	Site replication					
	Variation on Weather, demand, RES, etc					
	Agent based modelling	g - 🏹 😭				
- 🕄 🗎 🕻	Stochastic behavior	-				

Developed at EIFER - European Institute for Energy Research in Karlsruhe, Germany --- Copyright 2019 EIFER





Flexibility Potential Types

- 1. In total power (absolute potential):
 - Power that could be momentarily activated without any constraints (storage state, demand not considered)
- 2. In guaranteed power (usable potential for EVs):
 - Power potential that can be held during a predefined time duration (input). In this case, the duration of an average daily EV charging process (68 min, results of the EV charging hypothesis), considers prediction of demand
- 3. In flexible energy (absolute potential):
 - Total energy that can be shifted, without considering any power or time limits. Is calculated based on the current SOC and the prediction of the demand
 - Upward Flexibility Increase of consumption (e.g. heat pumps could be turned on)
 - Downward Flexibility Decrease of generation (e.g. heat pumps can be turned off)









119

Flexibility Potential Example



banomy **edf** GROUP



Flexibilty Simulation Cases



- 1. Baseline
 - Scenario for detached houses based on Scenario 1 ON-OFF of the Energy Study



- 2. Increased heat storage
 - Increase of the thermal storage for space heating



- 3. With batteries
 - Addition of a 3kWh battery to each home ____



- 4. Heat storage + batteries
 - **Combination of measure 2 and 3**



Synthesis of results

Number of EVs that can be additionally charged without increasing demand.











Synthesis of flexibility potential mapping

• Energy flexibility potentials up- and downwards for all cases*





*for visualisation purposes, color scales are relative to each plot and not absolutely comparable (see scaling in previous plots)

Strong increase with high correlation with solar

Copyright Urbanomy - 2021

140

Synthesis of results

- Heat storage (2) & Batteries (3)
- Increased heat storage leads to additional flexibility lacksquarepotential In terms of absolute energy potential up and downward In terms of downward guaranteed power potential adding 9% more EVs
- In general, the heat storage has low effect, as the flexibility emerging from heat pumps is not very large due to their low consumption and sizing.











• **Self consumption** is increased by 76% with batteries

Peak Reduction from Residential Flexibility



Comments and recommendations (1/2)

$\mathbf{01}$

Thermal demand vs. electricity demand

The highly efficient thermal systems, show a very low heat demand. The thermal demand is quite low compared to the electricity demand – which is usually the opposite in most district energy. This special situation leads to a low flexibility potential in the baseline, and it is only slightly increased when adding an additional thermal storage of 250l to the space heating systems. Even with large storages, the relatively low installed powers make this energy potential not usable, thus maintaining a low power flexibility potential.

Downward power potential is always available, allowing to charge additional vehicles by shifting the load due to heat pump stopping at the charging time. Downward energy potential is also useful when other loads would enter the system at critical peak times. In this case the terraced houses could reduce their loads and shift energy consumption to later moments.

Batteries & flexibility

Batteries show the largest effect on flexibility potential as they provide a real flexibility lever in both terms of energy and especially power.



Upward energy potential can be useful to absorb renewable electricity from other parts of the district for shorter durations than the minimum guaranteed value: e.g., if there is a CHP generating electricity, or if other parts of the district would increase their PV share.

Absolute upward energy potential

Absolute upward energy potential is relatively high compared to power potential, as it considers the theoretical available thermal capacity in the heat storages, as well as the spare capacity in the batteries (in scenario 3-4).





Downward power potential

N5

Upward power potential



Storage systems

The system simulated for Salt Cross Garden Village shows a low flexibility in the baseline simulation, but it can be considerably and effectively increased by electrical storage (i.e. batteries).

Increased flexibility potential

Increased thermal storage measures are only reasonable if the heating systems are largely sized. The use of batteries is recommended, as it allows to increase both PV self consumption and flexibility provision.



In order to harvest the flexibility potential, an energy management system should be set up for the district. This system should be well dimensioned, as it needs to be able to manage many small assets : more than 1500 individual heat pumps are expected and eventually batteries as well.



$\mathbf{08}$

Maximisation of local self-consumption

Local self-consumption of the Salt Cross Garden Village can be optimised by combining PV and power-to-heat storage to harvest most of the solar electricity by the heat pumps.



Energy management systems



6.2. Flexibility **Residential flexibility revenues**

In this section, the potential savings and revenues have been evaluated for the residential flexibility evaluated in the previous section.





Grid Energy Management (GEM) Optimisation tool

GEM-Storage tool (Grid Energy Management), is a 2stage optimisation model developed through a rolling horizon to evaluate the business case for energy storage assets in stand-alone configuration or co-located with a low carbon generator.

The model determines the **optimum (combined) asset(s)** operation based on price signals from various markets / services, namely: Day-Ahead market, Intraday market, Frequency Response service, Balancing Mechanism and non-energy energy costs. Fundamentally, and based on the various price signals, the model will determine the optimum operational strategy and quantify the associated revenue streams, over the assets lifetime.

Moreover, 4 battery degradation options are included in the model and available for selection based on user input including linear and bespoke degradation options.









Multi-Service Business Model: Definitions of the services





revenue reducing **Frequency Response (FR)**

- Provision is achieved in specific time blocks (i.e. EFA blocks)
- Modelled implicitly and not optimised

Multi-Service Business Model: Definitions of the services



- **DSO Services for SSEN**
- The flexibility provider is contracting for a period of time during which he will provide asset availability during the Availability window. For example, he will contract for 20 days of availability per month over a period of 3 months (60 days of availability).
- The availability must be during the Availability Window between 4pm and 8pm. This represents 60 days x 4h = 240h of availability.
- The foreseen price for the DSO services is £300/MWh for the utilisation of 20h within the frame of the above structure. If less than 20h are called, the payment will remain of £300/MW. In other words, from a total of 240h of being available, the DSO expects to activate the flexibility asset to deliver the DSO service for up to 20h.
- The contract value = £300/MWh for 20h of expected utilisation x MW of flexibility offered
- For the sake of this study, we have considered an equivalent price in terms of £/MW/h for each settlement period equal to £1.25/MW/HH = (£300/MWh ÷ 240h)

Copyright Urbanomy - 2021

GEM-Storage: Revenues / Costs Modelling



Case 4 integrates the highest potential for flexibility and has been highlighted here to display the highest revenues.

 Day-Ahead market prices 	BSUoS	
 DUoS BSUoS TNUoS / TRIADS 	• TNUoS / TRIADS	 Day-Ahead material Frequency restavailability fees DSO services DUoS BSUoS TNUoS / TRIA

COPENERGY

R&D UK Center

urbanomy

omposea by.



-Case 4-

Combined thermal

storage + battery

Case 4 exhibits a greater flexibility potential by considering an increased capacity in heat storage but also a residential battery. Costs / Revenues streams are composed by:

- Day-Ahead market prices
- Frequency response availability fees
- DSO services
- DUoS •
- BSUoS
- TNUoS / TRIADS

Input Data: Market Data & Assumptions



¹ – Frequency response service is based on FFR product from National Grid (more info here). Service delivery was considered during EFA block 2.

² – Availability price based on current market conditions for FFR product.

³ – Maximum availability price expected for LEO flexibility market, confirmed by SSEN.



that wholesale Note during Summer prices are usually associated lower prices in with absolute terms but also volatility. when less compared to Winter market conditions.

Non-Energy Costs are associated to a specific DNO area (here Southern zone 10).

Results Case 4 – Economic Benefits

Case 4 - Daily revenue per day in pounds for a typical day in Winter and Summe



banom

ODE GROU

R&D UK Center

er	Case 4 has been defined as the		
	combination of Case 2 and Case 3, with		
	the combination of thermal storage and		
าร	battery storage. This allows for higher		
	volumes of energy and power flexibility,		
	and therefore higher revenues (especially		
	in Summer).		

Comparatively to Cases 1 and 2, Case 4 exhibits an inverted trend for seasonal Summer revenues, revenues; are typically higher than in Winter due to:

- Higher volumes of flexibility available, due to lower energy requirements (e.g. heating not required)
- Increased production from PV plants, that are also complemented by the opportunity the battery offers

Summer

Copyright Urbanomy - 2021
Results Case 4 – Flexibility profile



- both in Winter and Summer, and also being constrained by limited volume of upwards energy flexibility in Summer.

R&D UK Center

Results Case 4 – DSO & FR – Economic Benefits



- Provision of DSO flexibility services is typically performed during peak demand conditions in the distribution network (i.e., between 16h and 20h); ٠
- In contrast, provision of Frequency Response (namely FFR product) is achieved in **pre-defined time windows** and for this case study this was assumed to be during ٠ EFA block 2 (i.e., between 03h and 07h);

*Arbitrage revenues include opportunity costs for DSO / resp. FR (see slide below)

anon R&D UK Cente

Comments and recommendations

01 Case 4 is the "best case" to maximise revenues

Case 4 (Combined thermal storage + batteries) is the scenario with the greatest volumes of flexibility. This allows for higher volumes of energy and power flexibility, and therefore higher revenues (especially in Summer). In the best case scenarios, the hypothetical maximum revenues can go up to:

- £22,400 /MW_{flex}/year for Arbitrage -
- £4,200 / MW_{flex}/year for DSO (not including opportunity costs which would reduce significantly the value)
- £22,000 / MW_{flex}/year for FR (not including opportunity costs which would reduce significantly the value)

One of the key observations based on the simulations is that providing DSO flexibility services allows flexibility providers to benefit from additional revenues related with the availability payments for the service. However, this entails an opportunity cost from market arbitrage. In other words, flexibility providers are likely to face higher electricity costs when providing DSO flexibility services.

Positive Impact of Energy Storage System on revenues

Higher volumes of energy and power flexibility (see case 3 and 4), and therefore higher revenues are a direct consequence of the presence of an Energy Storage System (ESS) (e.g. residential battery). In comparison with cases without an ESS (cases 1 and 2), the seasonal trend is inverted, with higher revenues in Summer due to lower energy requirements (e.g. heating not required) but also to an increased production from PV plants, that are also complemented by the opportunity that the ESS offers.



Similar results to those of DSO Services can be observed for Frequency Response, with the difference being that Frequency Response entails a lower opportunity cost.

The results of the simulations highlight that providing Frequency Response and seizing arbitrage opportunities in the wholesale market have higher synergies in terms of economic benefits than providing DSO services combined with seizing arbitrage opportunities. Frequency Response with daily arbitrage should consequently be preferred over DSO Service with daily arbitrage when making final flexibility choices for Salt Cross Garden Village.



Revenue and opportunity cost of DSO Services

Revenue and opportunity cost of Frequency Response

Frequency Response versus DSO services 05

6.3 Flexibility V1G-V2G





175

The Grid Energy Management Tool for V1G/V2G

To complement the previous section estimating the residential value, an estimation of the potential revenues from Smart charging (V1G) and Vehicle to Grid (V2G) follows. The pool of electric vehicles represented by the future development of Salt Cross Garden Village allows access to a significant aggregated storage capacity which can be managed to drive various strategies of flexibility and lead to economic benefits through various services.

The Grid Energy Management - EV tool is an optimization tool / model to evaluate the revenue streams for EVs providing grid services and operating on merchant markets. The tool is built on the same core functionalities already used as one of the module of EDF's virtual powerplant.





V1G/V2G - Revenues / Costs Modelling

Baseline

"Baseline" charging strategy considers the energy cost battery associated with charging actions once the EV is connected to the grid. Costs are composed by:

- Day-Ahead market prices
- DUoS
- BSUoS
- TNUoS / TRIADS

V1G

"V1G" charging strategy from "Baseline" by differs selecting the optimum market conditions for battery charging actions. Comparatively to Baseline, V1G determines the costs savings composed by:

- **Day-Ahead market** prices
- DUoS
- **BSUoS**
- TNUoS / TRIADS

V2G

"V2G" charging strategy considers potential the arbitrage energy opportunities by charging / discharging actions, while respecting energy mobility requirements for purposes:

- **Day-Ahead market** prices
- DUoS
- BSUoS •
- TNUOS / TRIADS





V2G + FR / DSO

"V2G + FR / DSO" charging strategy further explores the value of flexibility of V2G by considering provision of Frequency Response or DSO services. Costs / Revenues streams are composed by:

- Day-Ahead market prices
- Frequency response availability fees
- DSO services
- DUoS
- BSUoS
- TNUoS / TRIADS

V1G/V2G – Reminder of EV cases



Focus on case 3 of the EV scenarios are highlighted here as they represent the main opportunity for V1G and V2G.



edfenergy R&D UK Center

Results: Case 3 V1G Optimised Charging Profiles



- and Winter market conditions for V1G strategies.
- Case 3 is exhibiting the highest peak in consumption (i.e., 0.8 MW) due to the high EV penetration (38%) and due to the existence of 50kW chargers.
- The dip around 1:30am can be explained by a slightly higher price, resulting in no smart charging during this time.





Results: Case 3 | V2G Optimised Charging Profiles



Summer market conditions.



Results: Case 3 | Economic Benefits



- The reduction in charging costs, for Case 3, exhibit the highest reduction of all cases :
 - Up to 57% and 104% reduction, respectively for V1G and V2G in Winter
 - Up to 69% and 105% reduction, respectively for V1G and V2G in Summer •
 - Both in Summer and Winter and in favourable market condition, V2G allow a revenue of ca. £14/day
- This is due to a combination of factors:

COLUMN STATEMENT STATEMENTE STATEMENTE STATEMENTE STATEMENT STATEMENTE S

R&D UK Center

High EV penetration (38%) associated with the existence of 50kW chargers – which allow for enhanced arbitrage opportunities.

ODE GROU





Comments and recommendations

01

Setting up V1G and V2G strategies is key to making cost savings

V1G charging strategies can potentially reduce charging costs by up to 57% in Winter, and up to 69% in Summer. Full recovery of the charging costs can be achieved with V2G charging strategies, bringing additional revenues of ca. £14/day.



02

V2G is more sensitive to seasonality than V1G

Although market conditions differ between Summer and Winter periods, V1G charging profiles remain similar. In contrast, when considering V2G charging strategies, Winter market conditions result in a higher number of charge/discharge cycles comparatively to Summer periods.



03

Provision of flexibility services can enhance economic attractivity of V2G...

Provision of flexibility services, i.e., Frequency Response or DSO services, can support the business case for V2G with an additional revenue stream, although this may decrease energy arbitrage opportunities and thus increase cost associated with charging actions. Trade-off between the two services was observed.

04

... however, it may have a stronger impact on battery degradation

Increased number of charge/discharge cycles with V2G charging strategies may be detrimental for battery degradation. Battery degradation (i.e. limited number of cycles) not considered in preliminary studies but may be required in further analysis.

7. Overall integration and **Key recommendations**





Salt Cross Garden Village study: Results Overview



Reaching NZ is possible through:

High Fabric efficiency to keep space heating below <15kwh/m2/y.







Efficient lighting and appliances as the share of non-thermal needs will become significant in high standard fabric buildings. Smart home monitoring systems can contribute.

Increasing PV generation and/or exploring link with other local renewables





Efficient heat pump systems with advanced control to keep low energy demand for thermal needs.



Integrating urban design and choice of typologies within the development of the energy system to ensure optimised efficiency and operation.



V1G and V2G

Good building design including solar shading to avoid cooling needs in summer.

allowing to shift the peak

and reduce largely the

charging costs for EV.



Use flexibility

from building and transport assets that allow to reduce peak demand and increase self consumption.



Storage

Combining low potential of thermal flexibility with residential batteries to increase revenues.



Heat recovery from computing, focused on specialist office rather than on adding a large scale data centre



201



bringing renewable source of heat that can be used also as a seasonal storage in the condition of being able to reinject heat during the summer. Requires additional geological study.





Geothermal borehole system

Focusing on arbitrage revenues

mainly as some other services

have a significant opportunity cost.

Office Cooling

When required (specialist offices), active cooling in summer and passive cooling in winter allows to reinject heat in the borehole system and keep it efficient on the long run.

Ambient loop systems

potentially









Thank you!



London - Berlin - Paris



We would be happy to exchange further. Email us at <u>benjamin.mousseau@urbanomy.io</u>

www.urbanomy.io

